

Department of Energy

§ 835.1101

(1) Have completed radiation safety training, examinations, and performance demonstrations required for entry to the area and performance of the work; and

(2) Ensure that all escorted individuals comply with the documented radiation protection program.

(e) Radiation safety training shall be provided to individuals when there is a significant change to radiation protection policies and procedures that may affect the individual and at intervals not to exceed 24 months. Such training provided for individuals subject to the requirements of § 835.901(b)(1) and (b)(2) shall include successful completion of an examination.

[63 FR 59685, Nov. 4, 1998]

§§ 835.902–835.903 [Reserved]

Subpart K—Design and Control

§ 835.1001 Design and control.

(a) Measures shall be taken to maintain radiation exposure in controlled areas ALARA through physical design features and administrative control. The primary methods used shall be physical design features (e.g., confinement, ventilation, remote handling, and shielding). Administrative controls shall be employed only as supplemental methods to control radiation exposure.

(b) For specific activities where use of physical design features is demonstrated to be impractical, administrative controls shall be used to maintain radiation exposures ALARA.

[63 FR 59686, Nov. 4, 1998]

§ 835.1002 Facility design and modifications.

During the design of new facilities or modification of existing facilities, the following objectives shall be adopted:

(a) Optimization methods shall be used to assure that occupational exposure is maintained ALARA in developing and justifying facility design and physical controls.

(b) The design objective for controlling personnel exposure from external sources of radiation in areas of continuous occupational occupancy (2000 hours per year) shall be to maintain ex-

posure levels below an average of 0.5 mrem (5 microsieverts) per hour and as far below this average as is reasonably achievable. The design objectives for exposure rates for potential exposure to a radiological worker where occupancy differs from the above shall be ALARA and shall not exceed 20 percent of the applicable standards in § 835.202.

(c) Regarding the control of airborne radioactive material, the design objective shall be, under normal conditions, to avoid releases to the workplace atmosphere and in any situation, to control the inhalation of such material by workers to levels that are ALARA; confinement and ventilation shall normally be used.

(d) The design or modification of a facility and the selection of materials shall include features that facilitate operations, maintenance, decontamination, and decommissioning.

[58 FR 65485, Dec. 14, 1993, as amended at 63 FR 59686, Nov. 4, 1998]

§ 835.1003 Workplace controls.

During routine operations, the combination of physical design features and administrative controls shall provide that:

(a) The anticipated occupational dose to general employees shall not exceed the limits established at § 835.202; and

(b) The ALARA process is utilized for personnel exposures to ionizing radiation.

[63 FR 59686, Nov. 4, 1998]

Subpart L—Radioactive Contamination Control

SOURCE: 63 FR 59686, Nov. 4, 1998, unless otherwise noted.

§ 835.1101 Control of material and equipment.

(a) Except as provided in paragraphs (b) and (c) of this section, material and equipment in contamination areas, high contamination areas, and airborne radioactivity areas shall not be released to a controlled area if:

(1) Removable surface contamination levels on accessible surfaces exceed the removable surface contamination values specified in appendix D of this part; or

(2) Prior use suggests that the removable surface contamination levels on inaccessible surfaces are likely to exceed the removable surface contamination values specified in appendix D of this part.

(b) Material and equipment exceeding the removable surface contamination values specified in appendix D of this part may be conditionally released for movement on-site from one radiological area for immediate placement in another radiological area only if appropriate monitoring is performed and appropriate controls for the movement are established and exercised.

(c) Material and equipment with fixed contamination levels that exceed the total contamination values specified in appendix D of this part may be released for use in controlled areas outside of radiological areas only under the following conditions:

(1) Removable surface contamination levels are below the removable surface contamination values specified in appendix D of this part; and

(2) The material or equipment is routinely monitored and clearly marked or labeled to alert personnel of the contaminated status.

§ 835.1102 Control of areas.

(a) Appropriate controls shall be maintained and verified which prevent the inadvertent transfer of removable contamination to locations outside of radiological areas under normal operating conditions.

(b) Any area in which contamination levels exceed the values specified in appendix D of this part shall be controlled in a manner commensurate with the physical and chemical characteristics of the contaminant, the radionuclides present, and the fixed and removable surface contamination levels.

(c) Areas accessible to individuals where the measured total surface contamination levels exceed, but the removable surface contamination levels are less than, corresponding surface contamination values specified in appendix D of this part, shall be controlled as follows when located outside of radiological areas:

(1) The area shall be routinely monitored to ensure the removable surface contamination level remains below the

removable surface contamination values specified in appendix D of this part; and

(2) The area shall be conspicuously marked to warn individuals of the contaminated status.

(d) Individuals exiting contamination, high contamination, or airborne radioactivity areas shall be monitored, as appropriate, for the presence of surface contamination.

(e) Protective clothing shall be required for entry to areas in which removable contamination exists at levels exceeding the removable surface contamination values specified in appendix D of this part.

Subpart M—Sealed Radioactive Source Control

SOURCE: 63 FR 59686, Nov. 4, 1998, unless otherwise noted.

§ 835.1201 Sealed radioactive source control.

Sealed radioactive sources shall be used, handled, and stored in a manner commensurate with the hazards associated with operations involving the sources.

§ 835.1202 Accountable sealed radioactive sources.

(a) Each accountable sealed radioactive source shall be inventoried at intervals not to exceed six months. This inventory shall:

(1) Establish the physical location of each accountable sealed radioactive source;

(2) Verify the presence and adequacy of associated postings and labels; and

(3) Establish the adequacy of storage locations, containers, and devices.

(b) Except for sealed radioactive sources consisting solely of gaseous radioactive material or tritium, each accountable sealed radioactive source shall be subject to a source leak test upon receipt, when damage is suspected, and at intervals not to exceed six months. Source leak tests shall be capable of detecting radioactive material leakage equal to or exceeding 0.005 microcurie.

(c) Notwithstanding the requirements of paragraph (b) of this section, an accountable sealed radioactive